

Approval Number: 1409555
Test Report: M105790



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

9th October 2015

Compania Elaboradora De Caucho, SA-Coeca
Pol. Ind. Betono,
C/. Concejo, 4,
01013 Vitoria,
Alava,
Spain

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS - ETHYLENE PROPYLENE (EP) - MATERIAL ONLY.

5355

EP-60-PER/ESP-1. Black coloured, compression moulded ethylene propylene rubber material. Shore hardness 60. Tested in-radius size 1.0mm. For use with water up to 85°C.

APPROVAL NUMBER: 1409555

APPROVAL HOLDER: COMPANIA ELABORADORA DE CAUCHO, SA-COECA

The Scheme reserves the right to review approval.

Approval 1409555 is valid between September 2014 and September 2019

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in blue ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme